

ADDENDUM #7

KITSAP TRANSIT
Invitation for Bids
STC Construction
RFP #KT 21-734
November 17, 2021

60 Washington Ave. Ste.
200
Bremerton, WA 98337
Phone: 360.479.6962
Fax: 360.377.7086

www.kitsaptransit.org



Note: All Proposers shall acknowledge the receipt of this Addendum on their Bid Form. This Addendum contains the following:

I. Clarification of Bid Specification

I. Clarification of Bid Specifications

In conversations with structural steel fabricators and coatings firms there is a lot of confusion on the desired finish for the project steel components.

- Drawing sheet 131 notes “all steel shall be hot dipped galvanized after fabrication unless noted otherwise”
- Volume 2 Section 05 12 13 - 2.03A all components of AESS paint system to comply with coating system specified, submitted and approved per section 09 96 00
 - 2.04A 1) Provide surface preparations to meet SSPC-SP 6
 - 2.04B Shop Prime Structural Steel Members
- Section 05 50 00 – makes several references to 09 96 00
- Section 50 51 00 – References section 09 96 00
- Section 50 51 16 Galvanizing has its own independent section and this section does not contain a schedule of items to be galvanized
- Section 05 52 13 References 09 96 00
- Section 05 75 00 References 09 96 00

After reviewing the drawing notes and 05 specification sections, you ultimately end up at the 09 96 00 High Performance Coatings Section. 3.07 provides a generic coating schedule for the project which does not clarify which materials are to receive high performance coatings and which materials are to receive galvanizing, and this schedule conflicts with other specification sections and drawing notes.

Clarification: The intent of the spec is that all structural steel and steel fabrications are primed and painted per Section 09 96 00 00 – High Performance Coatings. The only items noted in the specs to be galvanized are bolts and anchors embedded in concrete.

Section 05 51 16 – Galvanizing describes the galvanizing process to be used if components require galvanizing, however as noted above, no steel items are called out to be galvanized in the specs other than bolts and anchors embedded in concrete.

ADDENDUM #7

The general note on sheet 131 is a general note and is superseded by the specifications per the Order of Precedence.

All other terms and conditions remain the same.

END ADDENDUM 7

Please remember to acknowledge this addendum.